

ILA REPORT



INDUSTRIAL LAB ANALYSIS, INC.
2240 Williamsburg Drive
Glen Dale, WV 26038
304-233-5595

Company: Century Mining	Sample No.: 06-05-558
Pit Identification: Sewage Treatment Plant	Date Received: 05-10-06
Sampling Point: 601 STP Effluent	Date Reported: 06-05-06
Sample Collected By: DR	Analyzed By: IM/BM
Time & Date Collected: 05-10-06 @ 1250	

Parameter	Result	Units	M D L	Ref MC	Preservative
C BOD ₅ Day	< 5.0	mg/l	5.0	405.1	None
T S S	< 1.0	mg/l	2.0	160.2	None
Ammonia	1.68	mg/l	0.5	350.2	H ₂ SO ₄

Ref. MC: Standard Methods for Examination of Water and Wastewater, 18th Edition, and
US EPA Methods for Chemical Analysis of Water and Waste.